



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0220/07/2016-17

Date : 02/08/2016

STACK EMISSION MONITORING RESULTS

Pipe Plant (GPCB ID:18036)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_Part - 1/2/3/7

Sr. No.	Particulars	Unit	S - 11	S - 17	S - 25	S - 26	S - 27
01	Date of Sampling	---	Not In Operation During The Visit	22/07/2016	22/07/2016	Not In Operation During The Visit	Not In Operation During The Visit
02	Time of sampling	Hr.		11.30	15.30		
03	Stack Attached to	---	Bitumin Drying Oven - I	Common stack Bitumin Drying Oven - II & Boiler	Shot Blasing - I	Shot Blasing - II	Shot Blasing - III
04	Air Pollution Control Measures	---	---	---	Bag Filter	Bag Filter	Bag Filter
05	Stack Height	Meter	32.8	32.8	10.0	10.0	10.0
06	Stack Diameter	Meter	1.375	1.375	0.41	0.41	1.125
07	Stack Temperature	°C	---	155	41	---	---
08	Ambient Temperature	°C	---	33	35	---	---
09	Average Velocity of Flue Gases	m/sec.	---	5.2	12.8	---	---
10	Isokinetic flow rate for P.M. Sampling	LPM	---	15	23	---	---
11	Gaseous Sampling Flow Rate	LPM	---	2.0	2.0	---	---
12	Permissible limits for PM	mg/Nm3	150	150	150	150	150
13	Measured Concentration of PM	mg/Nm3	---	61	21	---	---
14	Permissible limits for SO2	mg/Nm3	100 ppm	100 ppm	40	40	40
15	Measured Concentration of SO2	mg/Nm3	---	23.2	ND	---	---
16	Permissible limits for Nox	mg/Nm3	50 ppm	50 ppm	25	25	25
17	Measured Concentration of Nox	mg/Nm3	---	21.6	ND	---	---

Note : Minimum Detectable Limit of SO2 & Nox is 0.1 and 0.01 ppm respectively.

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100

Calibration due on 25/09/2016

N.D= Not Detectable

Royal Environment Auditing & Consultancy Service



Muney
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royalservice@live.com ■ admin@royalconsultancy.com

Ref. No. : 0221/07/2016-17

Date : 02/08/2016

STACK EMISSION MONITORING RESULTS

Pipe Plant (GPCB ID:18036)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_1/2/3/7

Sr. No.	Particulars	Unit	S - 8	S - 9	S - 15	S - 20	S - 22	S - 23
01	Date of Sampling	---	21/07/2016	14/07/2016	13/07/2016	15/07/2016	21/07/2016	11/07/2016
02	Time of sampling	Hr.	10.30	9.50	9.00	9.15	11.40	9.45
03	Stack Attached to	---	Common stack Mg Converter-I&II	Zn Coating - I	Zn Coating - II	Zn Coating - III	Mg Converter - III	Zn Coating - IV & V
04	Air Pollution Control Measures	---	Bag Filter	Cyclone Separator & Bag Filter	Cyclone Separator & Bag Filter	Cyclone Separator & Bag Filter	Bag Filter	Cyclone Separator & Bag Filter
05	Stack Height	Meter	30	30	30	30	30	30
06	Stack Diameter	Meter	0.5	0.6	0.6	0.6	0.5	0.9
07	Stack Temperature	°C	43	44	45	42	52	38
08	Ambient Temperature	°C	32	30	29	29	34	31
09	Average Velocity of Flue Gases	m/sec.	27.3	12.4	13.2	14.6	10.2	5.1
10	Isokinetic flow rate for P.M. Sampling	LPM	13	22	23	26	18	21
11	Gaseous Sampling Flow Rate	LPM	2.0	---	---	---	2.0	---
12	Permissible limits for PM	mg/Nm ³	150	20 (Zn)	20 (Zn)	20 (Zn)	150	20 (Zn)
13	Measured Concentration of PM	mg/Nm ³	55	17 (Zn)	12 (Zn)	10 (Zn)	34	11 (Zn)
14	Permissible limits for SO ₂	mg/Nm ³	40	NA	NA	NA	40	NA
15	Measured Concentration of SO ₂	mg/Nm ³	ND	---	---	---	ND	---
16	Permissible limits for Nox	mg/Nm ³	25	NA	NA	NA	25	NA
17	Measured Concentration of Nox	mg/Nm ³	1.3	---	---	---	0.8	---

Note : Minimum Detectable Limit of SO₂ & Nox is 0.1 and 0.01 ppm respectively.

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100

Calibration due on 25/09/2016

NA=Not Applicable
ND=Not Detectable

Royal Environment Auditing & Consultancy Service



Munaj
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royalservice@live.com ■ admin@royalconsultancy.com

Ref. No. : 0222/07/2016-17

Date : 02/08/2016

STACK EMISSION MONITORING RESULTS

Pipe Plant (GPCB ID:18036)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_1/2/3/7

Sr. No.	Particulars	Unit	S - 1	S - 2	S - 3	S - 4	S - 5	S - 6	S - 12	S - 18
01	Date of Sampling	---	12/07/2016	12/07/2016	12/07/2016	12/07/2016	12/07/2016	12/07/2016	13/07/2016	11/07/2016
02	Time of sampling	Hr.	9.15	9.50	10.40	11.30	15.30	16.40	15.20	10.00
03	Stack Attached to	---	Core Shop-I	Core Shop-II	Core Shop-III	Core Shop-IV	Core Shop-V	Core Shop-VI	Core Cleaning & Dusting-I	Core Cleaning & Dusting-II
04	Air Pollution Control Measures	---	---	---	---	---	---	---	Bag Filter	Bag Filter
05	Stack Height	Meter	30	30	30	30	30	30	30	30
06	Stack Diameter	Meter	0.584	0.584	0.584	0.584	0.584	0.584	0.6	0.6
07	Stack Temperature	°C	37	36	38	40	42	39	45	47
08	Ambient Temperature	°C	30	31	31	32	34	34	35	33
09	Average Velocity of Flue Gases	m/sec.	3.5	3.3	3.1	4.3	4.1	4.5	11.3	13.2
10	Isokinetic flow rate for P.M. Sampling	LPM	14	14	13	17	16	18	20	23
11	Gaseous Sampling Flow Rate	LPM	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0
12	Permissible limits for PM	mg/Nm ³	150	150	150	150	150	150	150	150
13	Measured Concentration of PM	mg/Nm ³	19	31	37	25	15	30	35	46
14	Permissible limits for SO ₂	mg/Nm ³	40	40	40	40	40	40	40	40
15	Measured Concentration of SO ₂	mg/Nm ³	2.2	2.6	1.9	2.1	2.5	1.7	ND	ND
16	Permissible limits for Nox	mg/Nm ³	25	25	25	25	25	25	25	25
17	Measured Concentration of Nox	mg/Nm ³	3.6	4.2	3.2	2.9	3.1	4.3	5.1	4.8

Note : Minimum Detectable Limit of SO₂ & Nox is 0.1 and 0.01 ppm respectively.

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100

Calibration due on 25/09/2016

ND= Not Detectable

Royal Environment Auditing & Consultancy Service



Mung
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royalservice@live.com ■ admin@royalconsultancy.com

Ref. No. : 0223/07/2016-17

Date : 02/08/2016

STACK EMISSION MONITORING RESULTS

Pipe Plant (GPCB ID:18036)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_1/2/3/7

Sr. No.	Particulars	Unit	S - 7	S - 10	S - 13	S - 14	S - 16	S - 19	S - 21	S - 24
01	Date of Sampling	---	13/07/2016	Not in operation during visit	15/07/2016	15/07/2016	Not in operation during visit	15/07/2016	Not in operation during visit	Not in operation during visit
02	Time of sampling	Hr.	10.00		9.45	10.50		15.10		
03	Stack Attached to	---	Sand Reclamation	Barrel Grinding - I	Annealing Furnace - I	Annealing Furnace - II	Barrel Grinding - II	Annealing Furnace - III	Barrel Grinding-III	Barrel Grinding -IV&V
04	Air Pollution Control Measures	---	Bag Filter	Bag Filter	---	---	Bag Filter	---	Bag Filter	Bag Filter
05	Stack Height	Meter	30	30	32	32	30	32	30	30
06	Stack Diameter	Meter	0.9	0.6	1.375	1.375	0.6	1.375	0.5	0.5
07	Stack Temperature	°C	86	...	167	163	...	165
08	Ambient Temperature	°C	32	...	35	35	...	35
09	Average Velocity of Flue Gases	m/sec.	14.7	...	3.9	4.1	...	4.2
10	Isokinetic flow rate for P.M. Sampling	LPM	23	...	11	12	...	12
11	Gaseous Sampling Flow Rate	LPM	2.0	...	2.0	2.0	...	2.0
12	Permissible limits for PM	mg/Nm3	150	150	150	150	150	150	150	150
13	Measured Concentration of PM	mg/Nm3	52	...	12	15	...	11
14	Permissible limits for SO2	mg/Nm3	40	40	100 (PPM)	100 (PPM)	40	100 (ppm)	40	40
15	Measured Concentration of SO2	mg/Nm3	5.2	...	2.1	2.5	...	3.3
16	Permissible limits for Nox	mg/Nm3	25	25	50 (PPM)	50 (PPM)	25	50 (PPM)	25	25
17	Measured Concentration of Nox	mg/Nm3	12.6	...	6.3 (PPM)	5.1 (PPM)	...	6.2 (PPM)

Note : Minimum Detectable Limit of SO2 & Nox is 0.1 and 0.01 ppm respectively.

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100

Calibration due on 25/09/2016

N.D= Not Detectable

Royal Environment Auditing & Consultancy Service



Mang
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0224/07/2016-17

Date : 02/08/2016

STACK EMISSION MONITORING RESULTS Pipe Plant (SDP-2) (GPCB ID:18036)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_1/2/3/7

Sr. No.	Particulars	Unit	S - 1	S - 2	S - 3	S - 4	S - 5	S - 6	S - 7	S - 8
01	Date of Sampling	---	19/07/2016	19/07/2016	19/07/2016	19/07/2016	16/07/2016	16/07/2016	Not in operation during visit	26/07/2016
02	Time of sampling	Hr.	9.00	11.30	15.20	16.25	9.45	14.40		10.00
03	Stack Attached to	---	Magnesium Treatment	Socket Cleaning	Annealing Furnace - I	Annealing Furnace - II	Zinc Coating	Tri- Grinding Section	Pre & Post Heating	Zinc Coating Machine
04	Air Pollution Control Measures	---	Bag Filter	Bag Filter	---	---	Bag Filler	Bag Filter	---	---
05	Stack Height	Meter	30	30	45	45	30	30	30	30
06	Stack Diameter	Meter	1.00	0.50	0.85	0.85	1.00	1.00	0.85	1.20
07	Stack Temperature	°C	41	36	129	125	38	36	---	37
08	Ambient Temperature	°C	29	30	31	31	30	34	---	33
09	Average Velocity of Flue Gases	m/sec	4.6	2.6	4.8	5.2	4.3	2.5	---	4.1
10	Isokinetic flow rate for PM Sampling	LPM	19	11	15	17	18	10	---	17
11	Gaseous Sampling Flow Rate	LPM	---	---	2.0	2.0	---	---	---	---
12	Permissible limits for PM	mg/Nm ³	50	50	50	50	50	50	50	50
13	Measured Concentration of PM	mg/Nm ³	30	16	11	14	26 (Zn)	22	---	16 (Zn)
14	Permissible limits for SO ₂	PPM	NA	NA	100	100	NA	NA	NA	NA
15	Measured Concentration of SO ₂	PPM	---	---	2.6	2.9	---	---	---	---
16	Permissible limits for NO _x	PPM	NA	NA	50	50	NA	NA	NA	NA
17	Measured Concentration of NO _x	PPM	---	---	3.7	4.2	---	---	---	---

Note : Minimum Detectable Limit of SO₂ & Nox is 0.1 and 0.01 ppm respectively.
Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100
Calibration due on 25/09/2016

ND= Not Detectable
N.A= Not Applicable

Royal Environment Auditing & Consultancy Service



Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0208/07/2016-17

Date : 02/08/2016

Performance Evaluation of Air Pollution Control Equipments

Sinter Plant-1 (GPCB ID 35456)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_Part - 1/3

Sr. No.	Particulars	Unit	S - 1	S - 2	S - 3	S - 6
01	Date of Sampling	---	07/07/2016	Not in operation during visit	07/07/2016	07/07/2016
02	Attached to	---	Fuel & Flux crusher & screening building	Fuel & Flux crushing house	Sinter Furnace	Discharge end
03	Stack Height	Meter	32	27	50	32
04	Stack Diameter	Meter	1.4	1.4	2.0	1.3
05	Stack Temperature	°C	49	...	155	148
06	Ambient Temperature	°C	35	...	29	31
07	Average Velocity of Flue Gases	m/sec.	13.3	...	34.6	30.4
08	IsoKinetic Flowrate for Sampling	LPM	23	...	11	10
09	Inlet	mg/Nm ³	2853	...	4151	3816
10	Outlet	mg/Nm ³	24	...	66	30
11	Efficiency	%	99.16	...	98.41	99.21

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100
Calibration due on 25/09/2016

Royal Environment Auditing & Consultancy Service



Mehar
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0209/07/2016-17

Date : 02/08/2016

Blast Furnace Plant-1(GPCB ID:18037)

Name of company : JINDAL SAW LIMITED,

Village: Samaghogha,

Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_Part - 1/3

Sr. No.	Particulars	Unit	S - 1
01	Date of Sampling	---	08/07/2016
02	Attached to	---	De-dustingSystem
03	Stack Height	Meter	35
04	Stack Duct Diameter	Meter	1.4
05	Stack Temperature	°C	52
06	Ambient Temperature	°C	34
07	Average Velocity of Flue Gases	m/sec.	14.9
08	IsoKinetic Flowrate for Sampling	LPM	26
09	Inlet	mg/Nm ³	597
10	Outlet	mg/Nm ³	4
11	Efficiency	%	99.33

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100

Calibration due on 25/09/2016



Royal Environment Auditing & Consultancy Service

Mamey
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royalservice@live.com ■ admin@royalconsultancy.com

Ref. No. : 0210/07/2016-17

Date : 02/08/2016

Performance Evaluation of Air Pollution Control Equipments

Sinter Plant-2 (GPCB ID:29017)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_Part - 1/3

Sr. No.	Particulars	Unit	S - 1	S - 2	S - 3	S - 7	S - 9	S-10
01	Date of Sampling	---	21/07/2016	Not in operation during visit	21/07/2016	20/07/2016	20/07/2016	20/07/2016
02	Attached to	---	Fuel crushing de-duster system (Fuel)	Fuel crushing de-duster system (Flux)	Fuel screening deduster system (Flux screening)	Sinter Furnace	Discharging end of Sinter de-dusting System	Pulverised Coal Injection
03	Stack Height	Meter	30	30	30	50	50	32
04	Stack Diameter	Meter	0.7	0.7	0.7	2.0	1.3	1.0
05	Stack Temperature	°C	45	49	162	130	141
06	Ambient Temperature	°C	32	34	30	33	34
07	Average Velocity of Flue Gases	m/sec.	13.8	12.2	36.3	33.1	15.4
08	IsoKinetic Flowrate for Sampling	LPM	24	21	12	12	21
09	Inlet	mg/Nm ³	2618	2819	4355	3013	1896
10	Outlet	mg/Nm ³	16	28	54	20	13
11	Efficiency	%	99.39	99.01	98.76	99.34	99.31

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100
Calibration due on 25/09/2016

Royal Environment Auditing & Consultancy Service

[Handwritten Signature]



[Handwritten Signature]
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0211/07/2016-17

Date : 02/08/2016

Performance Evaluation of Air Pollution Control Equipments Pipe Plant (GPCB ID:18036)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_Part - 1/3

Sr. No.	Particulars	Unit	S - 7	S - 8	S - 12	S - 18	S - 22
01	Date of Sampling	---	13/07/2016	21/07/2016	13/07/2016	13/07/2016	21/07/2016
02	Attached to		Sand Reclamation	Common stack Mg Converter - I & II	Core Cleaning & Dusting - I	Core Cleaning & Dusting - II	Mg Converter - III
03	Stack Height	Meter	32	30	30	30	30
04	Stack Diameter	Meter	0.9	0.5	0.6	0.6	0.5
05	Stack Temperature	°C	122	51	53	58	97
06	Ambient Temperature	°C	32	32	35	33	31
07	Average Velocity of Flue Gases	m/sec.	24.9	15.4	13.2	15.7	6.9
08	IsoKinetic Flowrate for Sampling	LPM	9	26	23	26	24
09	Inlet	mg/Nm ³	4952	4431	3813	4651	3751
10	Outlet	mg/Nm ³	52	55	35	46	34
11	Efficiency	%	98.95	98.76	99.08	99.01	99.09

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100
Calibration due on 25/09/2016

Royal Environment Auditing & Consultancy Service



Muney
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0212/07/2016-17

Date : 02/08/2016

Performance Evaluation of Air Pollution Control Equipments Pipe Plant (GPCB ID:18036)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_Part - 1/3

Sr. No.	Particulars	Unit	S - 9	S - 10	S - 15	S - 16	S - 20	S - 21	S - 23
01	Date of Sampling	---	14/07/2016	Not in operation during visit	13/07/2016	Not in operation during visit	15/07/2016	Not in operation during visit	11/07/2016
02	Attached to	---	Zinc Coating - I	Barrel Grinding-I	Zinc Coating - II	Barrel Grinding-II	Zinc Coating - III	Barrel Grinding-III	Zinc Coating - IV & V
03	Stack Height	Meter	30	30	30	30	30	30	30
04	Stack Duct Diameter	Meter	0.6	0.6	0.6	0.6	0.6	0.5	0.9
05	Stack Temperature	°C	51	...	53	...	50	...	45
06	Ambient Temperature	°C	30	...	29	...	29	...	31
07	Average Velocity of Flue Gases	m/sec.	14.1	...	14.9	...	16.2	...	15.1
08	IsoKinetic Flowrate for Sampling	LPM	24	...	25	...	28	...	26
09	Inlet	mg/Nm ³	1794	...	2013	...	1934	...	1648
10	Outlet	mg/Nm ³	17	...	12	...	10	...	11
11	Efficiency	%	99.05	...	99.40	...	99.48	...	99.33

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100
Calibration due on 25/09/2016

Royal Environment Auditing & Consultancy Service



meena
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royalservice@live.com ■ admin@royalconsultancy.com

Ref. No. : 0213/07/2016-17

Date : 02/08/2016

Performance Evaluation of Air Pollution Control Equipments

Pipe Plant (SDP-2) (GPCB ID:18036)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_Part - 1/3

Sr. No.	Particulars	Unit	S - 1	S - 5	S - 6	S-8
01	Date of Sampling	---	19/07/2016	16/07/2016	16/07/2016	20/07/2016
02	Attached to	---	Mg Treatment	Zinc Coating	Tri-Grinding	Zinc Coating machine
03	Stack Height	Meter	30	30	30	30
04	Stack Duct Diameter	Meter	1.00	1.00	1.00	0.8
05	Stack Temperature	°C	52	46	41	42
06	Ambient Temperature	°C	29	30	34	33
07	Average Velocity of Flue Gases	m/sec.	8.6	9.7	4.2	5.1
08	IsoKinetic Flowrate for Sampling	LPM	15	17	17	21
09	Inlet	mg/Nm ³	3162	3316	2494	1635
10	Outlet	mg/Nm ³	30	26	22	16
11	Efficiency	%	99.05	99.22	99.12	99.02

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100

Calibration due on 25/09/2016

Royal Environment Auditing & Consultancy Service



Mangal
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0214/07/2016-17

Date : 02/08/2016

Performance Evaluation of Air Pollution Control Equipments

Blast Furnace Plant-2 (GPCB ID:29026)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_Part - 1/3

Sr. No.	Particulars	Unit	S - 1	S - 4	S - 5
01	Date of Sampling	---	09/07/2016	09/07/2016	09/07/2016
02	Attached to	---	Dedusting System	Coke fine building dust collecting system	Iron Ore fine & Dust Collecting System
03	Stack Height	Meter	40	30	30
04	Stack Duct Diameter	Meter	1.5	0.85	0.65
05	Stack Temperature	°C	57	58	38
06	Ambient Temperature	°C	31	33	34
07	Average Velocity of Flue Gases	m/sec.	30.7	13.2	11.8
08	IsoKinetic Flowrate for Sampling	LPM	13	22	21
09	Inlet	mg/Nm ³	4280	1046	741
10	Outlet	mg/Nm ³	35	10	6
11	Efficiency	%	99.18	99.04	99.19

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100

Calibration due on 25/09/2016

Royal Environment Auditing & Consultancy Service



Mung
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. :0215/07/2016-17

Date : 02/08/2016

STACK EMISSION MONITORING RESULTS

Sinter Plant - 1(GPCB ID:35456)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_Part - 1/2/3/7

Sr. No.	Particulars	Unit	S - 1	S - 2	S - 3	S - 4	S - 5	S - 6
01	Date of Sampling	---	07/07/2016	Not in operation during visit	07/07/2016	NA	NA	07/07/2016
02	Time of sampling	---	13.45		9.00			10.15
03	Stack Attached to	---	Fuel & Flux Crusher and Screening building	Fuel & Flux Crushing House	Sinter Furnace	Primary Mixture House	Secondary Mixture House	Discharge End
04	Air Pollution Control Measures	---	Bag Filter	Bag Filter	ESP	ESP
05	Stack Height	Meter	32.0	27.00	50	19.75	36.08	32
06	Stack Diameter	Meter	1.40	1.40	2.0	1.25	1.25	1.30
07	Stack Temperature	°C	42	149	143
08	Ambient Temperature	°C	35	29	31
09	Average Velocity of Flue Gases	m/sec.	4.2	5.7	17.4
10	Isokinetic flow rate for P.M. Sampling	LPM	18	17	24
11	Gaseous Sampling Flow Rate	LPM	2.0
12	Permissible limits for PM	mg/Nm ³	150	150	150	150	150	150
13	Measured Concentration of PM.	mg/Nm ³	24	...	66	30
14	Permissible limits for SO ₂	ppm	NA	NA	100	NA	NA	NA
15	Measured Concentration of SO ₂	ppm	ND
16	Permissible limits for NO _x	ppm	NA	NA	50	NA	NA	NA
17	Measured Concentration of NO _x	ppm	5.3

Note : Minimum Detectable Limit of SO₂ & Nox is 0.1 and 0.01 ppm respectively.

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100

Calibration due on : 25/09/2016

NA= Not Applicable

ND=Not Detectable

Royal Environment Auditing & Consultancy Service



Mungj
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0216/07/2016-17

Date : 02/08/2016

STACK EMISSION MONITORING RESULTS

Sinter Plant -2 (GPCB ID:29017)

Name of company : JINDAL SAW LIMITED,

Village: Samaghogha,

Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_Part - 1/2/3/7

Sr. No.	Particulars	Unit	S - 1	S - 2	S - 3	S - 4	S - 5	S - 6	S - 7	S - 8	S - 9	S - 10
01	Date of Sampling	---	Not In Operation During The Visit	21/07/2016	21/07/2016	Not In Operation During The Visit	NA	NA	20/07/2016	Not In Operation During The Visit	20/07/2016	20/07/2016
02	Time of sampling	Hr.		9.45	11.15				9.15		10.45	15.15
03	Stack Attached to	---	Fuel crushing de-duster system (Flux)	Fuel crushing de-duster system(Fuel)	Fuel Screening deduster System (Flux Screening)	No. I Transfer Station De-duster System	Primary Mixer De-duster system	Secondary Mixer De-duster system	Sinter Furnace	Transfer station no. 4 & 5 dedusting system	Discharging End of sinter de-dusting system	Pulverized Coal Injection
04	Air Pollution Control Measures	---	Dust Collector	Dust Collector	Dust Collector	Dust Collector	Dust Collector	Dust Collector	ESP	Dust Collector	ESP	Bag Filter
05	Stack Height	Meter	30	30	30	30	20	30	50	30	50	32
06	Stack Diameter	Meter	0.7	0.7	0.7	0.7	---	---	2	---	1.3	1.00
07	Stack Temperature	°C	---	38	42	---	---	---	156	---	122	120
08	Ambient Temperature	°C	---	32	34	---	---	---	30	---	33	34
09	Average Velocity of Flue Gases	m/sec.	---	11.1	5.9	---	---	---	12.6	---	27.3	9.7
10	Isokinetic flow rate for P.M. Sampling	LPM	---	20	24	---	---	---	16	---	10	14
11	Gaseous Sampling Flow Rate	LPM	---	---	---	---	---	---	2.0	---	---	2.0
12	Permissible limits for PM	mg/Nm3	150	150	150	150	150	150	150	150	150	150
13	Measured Concentration of PM	mg/Nm3	---	16	28	---	---	---	54	---	20	13
14	Permissible limits for SO2	ppm	NA	NA	NA	NA	NA	NA	100	NA	NA	100 (ppm)
15	Measured Concentration of SO2	ppm	---	---	---	---	---	---	ND	---	---	0.97
16	Permissible limits for NOx	ppm	NA	NA	NA	NA	NA	NA	50	NA	NA	50 (ppm)
17	Measured Concentration of NOx	ppm	---	---	---	---	---	---	4.2	---	---	0.64

Note : Minimum Detectable Limit of SO2 & Nox is 0.1 and 0.01 ppm respectively.

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100

Calibration due on : 25/09/2016

NA= Not Applicable
ND= Not Detectable

Royal Environment Auditing & Consultancy Service



Mehraj
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royalservice@live.com ■ admin@royalconsultancy.com

Ref. No. :0217/07/2016-17

Date : 02/08/2016

STACK EMISSION MONITORING RESULTS

BLAST FURNACE - 2 (GPCB ID:29026)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_Part - 1/2/3/7

Sr. No.	Particulars	Unit	S - 1	S - 2	S - 3	S - 4	S - 5
01	Date of Sampling	---	09/07/2016	09/07/2016	Monitoring Not Possible	09/07/2016	09/07/2016
02	Time of sampling	Hr.	9.45	8.30		11.40	15.20
03	Stack Attached to	---	Dedusting System	Stove Stack	Flare Stack	Coke fine building dust collecting system	Iron Ore fine & Dust Collecting System
04	Air Pollution Control Measures	---	Bag Filter	---	---	Bag Filter	Bag Filter
05	Stack Height	Meter	40.0	65.0	45	30.0	30.0
06	Stack Diameter	Meter	1.5	2.250	---	---	0.85
07	Stack Temperature	°C	46	214	---	51	34
08	Ambient Temperature	°C	31	28	---	33	34
09	Average Velocity of Flue Gases	m/sec.	26.2	2.5	---	11.4	8.7
10	Isokinetic flow rate for P.M. Sampling	LPM	12	7	---	20	16
11	Gaseous Sampling Flow Rate	LPM	---	---	---	---	---
12	Permissible limits for PM	mg/Nm ³	150	150	150	150	150
13	Measured Concentration of PM.	mg/Nm ³	35	2	---	10	6
14	Permissible limits for SO ₂	mg/Nm ³	NA	NA	NA	NA	NA
15	Measured Concentration of SO ₂	mg/Nm ³	---	---	---	---	---
16	Permissible limits for NO _x	mg/Nm ³	NA	NA	NA	NA	NA
17	Measured Concentration of NO _x	mg/Nm ³	---	---	---	---	---

Note : Minimum Detectable Limit of SO₂ & Nox is 0.1 and 0.01 ppm respectively.

NA=Not Applicable

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100

Calibration due on 25/09/2016

Royal Environment Auditing & Consultancy Service



Mangj
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0218/07/2016-17

Date : 02/08/2016

STACK EMISSION MONITORING RESULTS

BLAST FURNACE-1 (GPCB ID:18037)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_Part - 1/2/3/7

Sr. No.	Particulars	Unit	S - 1	S - 2	S - 3	S - 4	S - 5
01	Date of Sampling	---	08/07/2016	08/07/2016	08/07/2016	08/07/2016	Monitoring Not Possible
02	Time of sampling	Hr.	14.30	9.15	10.45	8.00	
03	Stack Attached to	---	Dedusting System	Boiler - I	Boiler - II	Stove Stack	Flare Stack
04	Air Pollution Control Measures	---	Bag Filter	---	---	---	---
05	Stack Height	Meter	35.0	45	45	50.0	30
06	Stack Diameter	Meter	1.5	1.4	1.4	2.25	---
07	Stack Temperature	°C	43	175	179	215	---
08	Ambient Temperature	°C	34	30	31	28	---
09	Average Velocity of Flue Gases	m/sec.	11.7	4.2	4.5	3.1	---
10	Isokinetic flow rate for P.M. Sampling	LPM	21	12	13	8	---
11	Gaseous Sampling Flow Rate	LPM	2.0	2.0	2.0	2.0	---
12	Permissible limits for PM	mg/Nm ³	150	150	150	150	150
13	Measured Concentration of PM.	mg/Nm ³	4	8	10	3	---
14	Permissible limits for SO ₂	mg/Nm ³	40	40	40	40	40
15	Measured Concentration of SO ₂	mg/Nm ³	ND	ND	ND	ND	---
16	Permissible limits for NO _x	mg/Nm ³	25	25	25	25	25
17	Measured Concentration of Nox	mg/Nm ³	ND	ND	ND	ND	---

Note : Minimum Detectable Limit of SO₂ & Nox is 0.1 and 0.01 ppm respectively.

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100

Calibration due on 25/09/2016

N.D.=Not Detectable

Royal Environment Auditing & Consultancy Service



Mang
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0219/07/2016-17

Date : 02/08/2016

STACK EMISSION MONITORING RESULTS

Captive Power Plant (GPCB ID:18037)

Name of company : JINDAL SAW LIMITED,

Village: Samaghogha,

Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 11255_Part - 1/2/3/7

Sr. No.	Particulars	Unit	S - 1	S - 2	S - 3	S - 4
01	Date of Sampling	---	14/07/2016	13/07/2016	13/07/2016	Not In Operation
02	Time of sampling	Hr.	11.20	14.20	15.15	During The Visit
03	Stack Attached to	---	6000 KVA D.G.	3240 KVA D.G.	3240 KVA D.G.	1180 KVA D.G.
04	Air Pollution Control Measures	---	---	---	---	---
05	Stack Height	Meter	57.0	35	35	35
06	Stack Diameter	Meter	1.984	1.484	1.484	0.980
07	Stack Temperature	°C	263	248	241	---
08	Ambient Temperature	°C	34	35	35	---
09	Average Velocity of Flue Gases	m/sec.	34.2	30.6	28.8	---
10	Isokinetic flow rate for P.M. Sampling	LPM	9	8	8	---
11	Gaseous Sampling Flow Rate	LPM	2.0	2.0	2.0	---
12	Permissible limits for PM	mg/Nm ³	150	150	150	150
13	Measured Concentration of PM.	mg/Nm ³	64	67	56	---
14	Permissible limits for SO ₂	ppm	100	100	100	100
15	Measured Concentration of SO ₂	ppm	29.4	27.5	24.9	---
16	Permissible limits for Nox	ppm	50	50	50	50
17	Measured Concentration of Nox	ppm	25.8	22.7	23.8	---

Note : Minimum Detectable Limit of SO₂ & Nox is 0.1 and 0.01 ppm respectively.

Instrument Used : Stack Monitoring Kit - Ecotech make - ESS 100

Calibration due on 25/09/2016

Royal Environment Auditing & Consultancy Service



Muney
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0230/07/2016-17

Date : 02/08/2016

WORK ZONE NOISE LEVEL MEASUREMENT

SINTER PLANT- 1 (GPCB ID:35456)

Name of company : JINDAL SAW LIMITED,

Village: Samaghogha,

Tal. : Mundra, Dist. Kutch

Date of sampling : 15th July, 2016

Sr. No.	Location of Sampling	Value in dB(A)		
		Min.	Max.	Leq
1	Inside Control Room	42.6	48.1	44.3
2	Inside Mechanical Room	48.9	54.3	50.2
3	Inside Electrical Room	47.5	52.9	49.1
4	Inside Plant Office	52.2	59.3	54.2

Instruments used : Sound level meter, Model : SL - 4030 (Lutron Make)

Range : A - 30 to 80 dB, B-50 to 100 dB, C-80 to 130 dB.

Recalibration is due on : 25/09/2016

Royal Environment Auditing & Consultancy Service



Munaf
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royalservice@live.com ■ admin@royalconsultancy.com

Ref. No. : 0235/07/2016-17

Date : 02/08/2016

WORK ZONE NOISE LEVEL MEASUREMENT

SINTER PLANT - 2 (29017)

Name of company : JINDAL SAW LIMITED,

Village: Samaghogha,

Tal. : Mundra, Dist. Kutch

Date of sampling : 15th July, 2016

Sr. No.	Location of Sampling	Value in dB(A)		
		Min.	Max.	Leq
01.	Inside Control Room	50.1	52.3	51.4
02.	Inside Operator Room	59.2	64.4	60.3
03.	Near Proportioning Bulding	63.4	65.3	65.2
04.	Near Crusher House	67.3	75.2	70.4

Instruments used : Sound level meter, Model : SL - 4030 (Lutron Make)

Range : A - 30 to 80 dB, B-50 to 100 dB, C-80 to 130 dB.

Recalibration is due on : 25/09/2016

Royal Environment Auditing & Consultancy Service

Signature



meung
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royalservice@live.com ■ admin@royalconsultancy.com

Ref. No. : 0231/07/2016-17

Date : 02/08/2016

WORK ZONE NOISE LEVEL MEASUREMENT BLAST FURNACE- 1 (GPCB ID:18037)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Date of sampling : 15th July, 2016

Sr. No.	Location of Sampling	Value in dB(A)		
		Min.	Max.	Leq
01.	Nr. Stock House	64.5	75.2	67.5
02.	Inside Control Room	45.9	55.3	48.2
03.	Inside Control room of Cast House	47.2	51.8	49.1
04.	Inside Laboratory	43.4	48.5	44.5
05.	Inside Control Room of Blower House	57.1	63.2	59.8
06.	Inside Control Room of CPP	53.4	62.4	55.1

Instruments used : Sound level meter, Model : SL - 4030 (Lutron Make)

Range : A - 30 to 80 dB, B-50 to 100 dB, C-80 to 130 dB.

Recalibration is due on : 25/09/2016

Royal Environment Auditing & Consultancy Service



Munraj
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0232/07/2016-17

Date : 02/08/2016

WORK ZONE NOISE LEVEL MEASUREMENT PIPE PLANT (GPCB ID:18036)

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Date of sampling : 15th July, 2016

Sr. No.	Location of Sampling	Value in dB(A)		
		Min.	Max.	Leq
01.	Inside Control Room of Annealing Furnace of DISP / SDP	49.3	53.9	51.8
02	Inside Control Room – Mill Area of Spiral Plant	60.9	64.8	61.5
03	Nr. Pipe Cutting Area of Spiral Plant	67.9	78.1	73.1
04	Inside JCO Plant	65.4	76.3	67.8
05	Inside DISP / SDP Plant	69.4	79.8	74.2
06	Inside Coating Plant	65.8	75.1	70.8
07	Nr. CCM SDP-2	63.8	72.9	67.4
08	Inside Control Room of Annealing Furnace of SDP-2	50.9	55.2	52.1
09	Nr. Zinc Coating SDP-2	67.2	78.3	73.4
10	Near Mould Shop	77.5	88.1	78.8

Instruments used : Sound level meter, Model : SL - 4030 (Lutron Make)

Range : A - 30 to 80 dB, B-50 to 100 dB, C-80 to 130 dB.

Recalibration is due on : 25/09/2016



Royal Environment Auditing & Consultancy Service

Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royalservice@live.com ■ admin@royalconsultancy.com

Ref. No. : 0233/07/2016-17

Date : 02/08/2016

AMBIENT NOISE LEVEL MEASUREMENT

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Date of sampling : 16th July, 2016

Sr. No.	Location of Sampling	Value in dB(A) Day Time			Value in dB(A) Night Time		
		Min.	Max.	Leq	Min.	Max.	Leq
01.	Admin. Building	42.1	50.2	43.1	37.2	43.1	39.4
02.	Old Colony	36.2	40.6	38.1	31.5	39.2	33.4
03.	Nr. LPG Yard	51.9	61.3	53.2	48.3	54.2	50.3
04.	New Colony (School)	36.8	43.4	39.1	34.5	38.3	35.1
05.	Nr. SDP-2	56.3	64.2	57.2	52.7	59.1	55.6
06.	Nr. Coating Plant	54.1	62.8	58.1	51.1	61.3	54.2
07.	Nr. Gate No. 2	55.3	62.1	57.7	48.8	57.2	50.4
08.	Nr. Sinter Plant-1	60.2	64.8	61.1	53.2	58.8	55.5
09.	Nr. Sinter Plant-2	57.1	66.2	60.2	54.3	60.2	56.1
10.	Nr. Blast Furnace-1	56.2	60.3	57.8	51.2	58.4	53.2
11.	Nr. Blast Furnace-2	55.1	61.2	56.9	45.3	50.8	48.3
12.	Nr. Main Gate (Security Office)	42.8	51.7	46.1	39.1	44.3	40.9

Instruments used : Sound level meter, Model : SL - 4030 (Lutron Make)

Range : A - 30 to 80 dB, B-50 to 100 dB, C-80 to 130 dB.

Recalibration is due on : 25/09/2016

Royal Environment Auditing & Consultancy Service



Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0236/07/2016-17

Date : 02/08/2016

REPORT OF DOMESTIC WASTE WATER ANALYSIS

Name of company : JINDAL SAW LIMITED,
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Source of Sample Collection : Sewage Treatment Plant (Inlet & Outlet)

Date of Sampling : 29/07/2016

Test Method : As per IS Standards - 3024

Sr. No.	Parameters	Unit	GPCB limits for Treated Effluent	Raw Sewage	Treated Effluent
01.	pH	pH Unit	---	7.67	7.35
02.	BOD (3 Days at 27°C)	mg/l	<20	183	11
03.	Total Dissolve Solid	mg/l	...	1159	1384
04.	COD	mg/l	...	248	25
05.	Total Suspended Solid	mg/l	<30	263	18
06.	Oil & Grease	mg/l	...	ND	ND
07.	Residual Chlorine	mg/l	Min. 0.5	---	0.67

ND=Not Detectable

Royal Environment Auditing & Consultancy Service



Mehang
Analyst

Ref. No. : 0225/07/2016-17


Date : 02/08/2016

Form No. 37
(Prescribed under Rule 12-B)

Register containing particulars of monitoring of working environment required under Section 7-A (a)(e).

- 1 Name of the Department/Plant.: **Sinter Plant-2 at JINDAL SAW LIMITED, Samaghogha. (GPCB ID:29017)**
- 2 Raw materials, by products and finished products involved in the process. **TOTAL DUST**
- 3 Particulars of sampling

Date of Sampling : 18th July, 2016

Sr. No	Location Operation monitored	Identified Contaminate	Sampling Instrument used	Airborne Contamination			TWA concentration (As given in Second Schedule)	Reference Method	Number of workers exposed at the location being monitored	Remarks	Signature of person taking samples	Name (in block letters)
				Number of sample	Range	Average	mg/m3					
1	Sinter Plant- At First Floor	Total Dust	Personal Respirable Dust sampler IAS 001	02	4-7	5.5	10	Gravimetric	3	---		Mr. MANOJ SONRAT

Instruments used : Envirotech make personal sampler, Model No. IAS 001

Calibration Due on. : 02/11/2016

For. Royal Environment Auditing & Consultancy Service




Authorized Sign

Form No. 37
(Prescribed under Rule 12-B)

Register containing particulars of monitoring of working environment required under Section 7-A (a)(e).

1 Name of the Department/Plant.: **Sinter Plant-1 at JINDAL SAW LIMITED, Samaghogha. (GPCB ID: 35456)**

2 Raw materials, by products and finished products involved in the process. **TOTAL DUST**

3 Particulars of sampling

Date of Sampling : 18th July, 2016

Sr. No	Location Operation monitored	Identified Contaminate	Sampling Instrument used	Airborne Contamination			TWA concentration (As given in Second Schedule)	Reference Method	Number of workers exposed at the location being monitored	Remark	Signature of person taking samples	Name (in block letters)
				Number of sample	Range	Average	mg/m3					
1	Sinter Plant At First Floor	Total Dust	Personal Respirable Dust sampler IAS 001	02	4-5	4.5	10	Gravimetric	4	---	<i>Mung</i>	Mr. MANOJ SONRAT

Instruments used : Envirotech make personal sampler, Model No. IAS 001

Calibration Due on. : 02/11/2016

For. Royal Environment Auditing & Consultancy Service



Mung
Authorized Sign

Ref. No. : 0227/07/2016-17

Date : 02/08/2016

Form No. 37
(Prescribed under Rule 12-B)

Register containing particulars of monitoring of working environment required under Section 7-A (a)(e).

- 1 Name of the Department/Plant.: **BF Plant-1 at JINDAL SAW LIMITED, Samaghogha. (GPCB ID: 18037)**
- 2 Raw materials, by products and finished products involved in the process. **TOTAL DUST & CO.**
- 3 Particulars of sampling

Date of Sampling : 18th July, 2016

Sr. No	Location Operation monitored	Identified Contaminate	Sampling Instrument used	Airborne Contamination			TWA concentration (As given in Second Schedule)	Reference Method	Number of workers exposed at the location being monitored	Remark	Signature person taking samples	Name (in block letters)
				Number of sample	Range	Average	mg/m3					
1	BF Plant (Cast House)	CO	Personal Respirable Dust sampler IAS 001	02	17-20	18.5	55	Gravimetric	5	---	<i>Money</i>	Mr. MANOJ SONRAT
		Total Dust			5-7	6.0	10					

Instruments used : Envirotech make personal sampler, Model No. IAS 001
Calibration Due on. : 02/11/2016

For. Royal Environment Auditing & Consultancy Service

Money
Authorized Sign



Form No. 37
(Prescribed under Rule 12-B)

Register containing particulars of monitoring of working environment required under Section 7-A (a)(e).

1 Name of the Department/Plant.: **BF Plant-2 at JINDAL SAW LIMITED, Samaghogha. (GPCB ID: 29026)**

2 Raw materials, by products and finished products involved in the process. **TOTAL DUST & CO.**

3 Particulars of sampling

Date of Sampling : 18th July, 2016

Sr. No	Location Operation monitored	Identified Contaminate	Sampling Instrument used	Airborne Contamination			TWA concentration (As given in Second Schedule) mg/m3	Refrance Method	Number of workers exposed at the location being monitored	Remark	Signature person taking samples	Name (in block letters)
				Number of sample	Range	Average						
1	BF Plant (Cast House)	CO	Personal Respirable Dust sampler IAS 001	02	17-18	17.5	55	Gravimetric	4	---	<i>Mung'</i>	Mr. MANOJ SONRAT
		Total Dust			4-6	5.0	10					

Instruments used : Envirotech make personal sampler, Model No. IAS 001

Calibration Due on. : 02/11/2016

For. Royal Environment Auditing & Consultancy Service



[Signature]
Authorized Sign

Ref. No. : 0229/07/2016-17

Date : 02/08/2016

**Form No. 37
(Prescribed under Rule 12-B)**

Register containing particulars of monitoring of working environment required under Section 7-A (a)(e).

- 1 Name of the Department/Plant.: **DISP, JCO & Coating Units at JINDAL SAW LIMITED, Samaghogha.(GPCB ID: 18036)**
- 2 Raw materials, by products and finished products involved in the process. **TOTAL DUST**
- 3 Particulars of sampling

Date of Sampling : 19th & 20th July, 2016

Sr. No	Location Operation monitored	Identified Contaminate	Sampling Instrument used	Airborne Contamination			TWA concentration (As given in Second Schedule)	Reference Method	Number of workers exposed at the location being monitored	Remark	Signature of person taking samples	Name (in block letters)
				Number of sample	Range	Average	mg/m3					
1	Spiral Plant (Nr. ID/OD)	Total Dust	Personal Respirable Dust sampler IAS 001	02	2-3	2.5	10	Gravimetric	4	---	<i>Manoj</i>	Mr. MANOJ SONRAT
2	JCO Plant (Nr. JCO Press)	Total Dust		02	3-5	4.0	10	Gravimetric	4	---		
3	Coating Plant-1 (Shot Blasting Area)	Total Dust		02	4-5	4.5	10	Gravimetric	3	---		
4	CCM Area (SDP / DISP)	Total Dust		02	6-7	6.5	10	Gravimetric	4	---		
5	Coating Plant-2 (Shot Blasting Area)	Total Dust		02	3-4	3.5	10	Gravimetric	3	---		
6	CCM Area (SDP-2)	Total Dust		02	5-7	6.0	10	Gravimetric	5	---		

Instruments used : Envirotech make personal sampler, Model No. IAS 001

Calibration Due on. : 02/11/2016



For. Royal Environment Auditing & Consultancy Service

Manoj
Authorized Sign



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royalservice@live.com ■ admin@royalconsultancy.com

Ref. No. : 0234/07/2016-17

Date : 02/08/2016

WORK ZONE NOISE LEVEL MEASUREMENT BLAST FURNACE - 2 (GPCB ID:29026)

Name of company : JINDAL SAW LIMITED,

Village: Samaghogha,

Tal. : Mundra, Dist. Kutch

Date of sampling : 15th July, 2016

Sr. No.	Location of Sampling	Value in dB(A)		
		Min.	Max.	Leq
01.	Inside Control Room	57.1	62.2	58.2
02.	Nr. Stock House	64.2	68.7	66.3
03.	C/R Blower House	65.7	74.1	68.1

Instruments used : Sound level meter, Model : SL - 4030 (Lutron Make)

Range : A - 30 to 80 dB, B-50 to 100 dB, C-80 to 130 dB.

Recalibration is due on : 25/09/2016

Royal Environment Auditing & Consultancy Service

Mamaj
Analyst





Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0201/07/2016-17

Date : 02/08/2016

NATIONAL AMBIENT AIR QUALITY MONITORING REPORT FOR THE MONTH - JULY : 2016

Name of company : JINDAL SAW LIMITED
 Village: Samaghogha,
 Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 5182_2/6/10/23

Sr. No.	Particulars	Unit	Location No.1 : Weigh Bridge (Nr.Gate No-2) (E)								
			01	02	03	04	05				
01.	No. of Week	---									
02.	Date & Time Starting of Monitoring	---	01/07/2016; 08.00	04/07/2016; 08.20	08/07/2016; 08.15	11/07/2016; 08.00	15/07/2016; 08.45	18/07/2016; 08.35	22/07/2016; 08.20	25/07/2016; 08.10	29/07/2016; 08.20
03.	Date & Time Ending of Monitoring	---	02/07/2016; 08.00	05/07/2016; 08.20	09/07/2016; 08.15	12/07/2016; 08.00	16/07/2016; 08.45	19/07/2016; 08.35	23/07/2016; 08.20	26/07/2016; 08.10	30/07/2016; 08.20
04.	Duration of Sampling	Min.	1440.00	1440.00	1440.00	1440.00	1440.00	1440.00	1440.00	1440.00	1440.00
05.	Dominant Wind Direction (From)	---	SSW	WSW	WSW	WSW	W	WSW	W	W	W
06.	Average Wind Speed	Km/Hr.	7.4	13.2	15.2	15.0	1.6	7.0	12.3	10.8	10.4
07.	Average flow rate for Dust Monitoring PM ₁₀	m ³ /min.	1.14	1.15	1.17	1.16	1.15	1.16	1.17	1.18	1.19
08.	Average flow rate for Dust Monitoring PM _{2.5}	m ³ /hr.	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
09.	Average flow rate for Gas Monitoring	LPM	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
10.	Permissible limits for PM ₁₀ *	µg/m ³	100	100	100	100	100	100	100	100	100
11.	Measured Concentration of PM ₁₀	µg/m ³	56	60	52	54	58	48	49	43	46
12.	Permissible limits for PM _{2.5} *	µg/m ³	60	60	60	60	60	60	60	60	60
13.	Measured Concentration of PM _{2.5}	µg/m ³	24	20	22	18	25	20	18	23	22
14.	Permissible limits for SO ₂ *	µg/m ³	80	80	80	80	80	80	80	80	80
15.	Measured Concentration of SO ₂	µg/m ³	5.3	4.6	3.8	4.4	5.1	4.7	3.9	3.5	3.3
16.	Permissible limits for NO ₂ *	µg/m ³	80	80	80	80	80	80	80	80	80
17.	Measured Concentration of NO ₂	µg/m ³	16.7	17.5	18.1	16.4	17.1	12.7	11.5	10.7	9.8
18.	Permissible limit for CO **	µg/m ³	2000	2000	2000	2000	2000	2000	2000	2000	2000
19.	Measured Concentration of CO	µg/m ³	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.

Instrument used : (1) 3 Nos. RDS (APM - 217 BL), (2) 3 Nos. of Gaseous Sampler (AAS 109) (3) 3 Nos. PM 2.5 Sampler (AAS 127)

All Calibration due on : 15/05/2017

*Permissible Limits are as per NAAQ Standard 16th November 2009.

B.D.L= Below Detectable Limit

Royal Environment Auditing & Consultancy Service



Mehraj
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0202/07/2016-17

Date : 02/08/2016

NATIONAL AMBIENT AIR QUALITY MONITORING REPORT FOR THE MONTH - JULY : 2016

Name of company : JINDAL SAW LIMITED
 Village: Samaghogha,
 Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 5182_2/6/10/23

Sr. No.	Particulars	Unit	Location No.2 : Sinter plant - 1 (NNW)								
			01	02	03	04	05	06	07	08	09
01.	No. of Week	----	01	02	03	04	05	06	07	08	09
02.	Date & Time Starting of Monitoring	----	01/07/2016; 08.15	04/07/2016; 08.35	08/07/2016; 08.30	11/07/2016; 08.20	15/07/2016; 08.05	18/07/2016; 08.55	22/07/2016; 08.40	25/07/2016; 08.25	29/07/2016; 08.40
03.	Date & Time Ending of Monitoring	----	02/07/2016; 08.15	05/07/2016; 08.35	09/07/2016; 08.30	12/07/2016; 08.20	16/07/2016; 08.05	19/07/2016; 08.55	23/07/2016; 08.40	26/07/2016; 08.25	30/07/2016; 08.40
04.	Duration of Sampling	Min.	1440.00	1440.00	1440.00	1440.00	1440.00	1440.00	1440.00	1440.00	1440.00
05.	Dominant Wind Direction (From)	----	SSW	WSW	WSW	WSW	W	WSW	W	W	W
06.	Average Wind Speed	Km/Hr.	7.4	13.2	15.2	15.0	1.6	7.0	12.3	10.8	10.4
07.	Average flow rate for Dust Monitoring PM ₁₀	m ³ /min.	1.14	1.18	1.17	1.20	1.19	1.18	1.16	1.15	1.14
08.	Average flow rate for Dust Monitoring PM _{2.5}	m ³ /hr.	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
09.	Average flow rate for Gas Monitoring	LPM	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
10.	Permissible limits for PM ₁₀ *	µg/m ³	100	100	100	100	100	100	100	100	100
11.	Measured Concentration of PM ₁₀	µg/m ³	52	55	54	50	43	47	45	54	53
12.	Permissible limits for PM _{2.5} *	µg/m ³	60	60	60	60	60	60	60	60	60
13.	Measured Concentration of PM _{2.5}	µg/m ³	20	18	16	15	21	16	20	22	24
14.	Permissible limits for SO ₂ *	µg/m ³	80	80	80	80	80	80	80	80	80
15.	Measured Concentration of SO ₂	µg/m ³	3.5	2.6	2.2	2.8	3.3	4.1	4.5	3.1	2.6
16.	Permissible limits for NO ₂ *	µg/m ³	80	80	80	80	80	80	80	80	80
17.	Measured Concentration of NO ₂	µg/m ³	13.7	16.4	17.7	16.5	17.4	18.3	15.7	14.6	11.4
18.	Permissible limit for CO **	µg/m ³	2000	2000	2000	2000	2000	2000	2000	2000	2000
19.	Measured Concentration of CO	µg/m ³	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.

Instrument used : (1) 3 Nos. RDS (APM - 217 BL), (2) 3 Nos. of Gaseous Sampler (AAS 109) (3) 3 Nos. PM 2.5 Sampler (AAS 127)

All Calibration due on : 15/05/2017

*Permissible Limits are as per NAAQ Standard 16th November 2009.

B.D.L= Below Detectable Limit

Royal Environment Auditing & Consultancy Service



Mehngi
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0203/07/2016-17

Date : 02/08/2016

NATIONAL AMBIENT AIR QUALITY MONITORING REPORT FOR THE MONTH - JULY : 2016

Name of company : JINDAL SAW LIMITED
 Village: Samaghogha,
 Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 5182_2/6/10/23

Sr. No.	Particulars	Unit	Location No.3 : Nr. Work Shop Spiral-II (W)								
			01	02		03		04		05	
01.	No. of Week	----									
02.	Date & Time Starting of Monitoring	----	01/07/2016; 08.35	04/07/2016; 08.55	08/07/2016; 08.50	11/07/2016; 08.40	15/07/2016; 08.25	18/07/2016; 09.15	22/07/2016; 09.00	25/07/2016; 08.45	29/07/2016; 09.05
03.	Date & Time Ending of Monitoring	----	02/07/2016; 08.35	05/07/2016; 08.55	09/07/2016; 08.50	12/07/2016; 08.40	16/07/2016; 08.25	19/07/2016; 09.15	23/07/2016; 09.00	26/07/2016; 08.45	30/07/2016; 09.05
04.	Duration of Sampling	Min.	1440.00	1440.00	1440.00	1440.00	1440.00	1440.00	1440.00	1440.00	1440.00
05.	Dominant Wind Direction (From)	----	SSW	WSW	WSW	WSW	W	WSW	W	W	W
06.	Average Wind Speed	Km/Hr.	7.4	13.2	15.2	15.0	1.6	7.0	12.3	10.8	10.4
07.	Average flow rate for Dust Monitoring PM ₁₀	m ³ /min.	1.23	1.22	1.21	1.20	1.19	1.24	1.23	1.22	1.23
08.	Average flow rate for Dust Monitoring PM _{2.5}	m ³ /hr.	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
09.	Average flow rate for Gas Monitoring	LPM	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
10.	Permissible limits for PM ₁₀ *	µg/m ³	100	100	100	100	100	100	100	100	100
11.	Measured Concentration of PM ₁₀	µg/m ³	40	37	45	36	32	36	39	33	38
12.	Permissible limits for PM _{2.5} *	µg/m ³	60	60	60	60	60	60	60	60	60
13.	Measured Concentration of PM _{2.5}	µg/m ³	14	13	15	18	16	19	20	17	12
14.	Permissible limits for SO ₂ *	µg/m ³	80	80	80	80	80	80	80	80	80
15.	Measured Concentration of SO ₂	µg/m ³	2.2	1.9	2.6	3.2	3.8	2.9	2.7	3.1	2.4
16.	Permissible limits for NO ₂ *	µg/m ³	80	80	80	80	80	80	80	80	80
17.	Measured Concentration of NO ₂	µg/m ³	9.4	10.1	11.4	13.2	12.3	13.2	10.5	9.6	8.7
18.	Permissible limit for CO **	µg/m ³	2000	2000	2000	2000	2000	2000	2000	2000	2000
19.	Measured Concentration of CO	µg/m ³	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.	B.D.L.

Instrument used : (1) 3 Nos. RDS (APM - 217 BL), (2) 3 Nos. of Gaseous Sampler (AAS 109) (3) 3 Nos. PM 2.5 Sampler (AAS 127)

All Calibration due on : 15/05/2017

*Permissible Limits are as per NAAQ Standard 16th November 2009.

B.D.L.= Below Detectable Limit

Royal Environment Auditing & Consultancy Service



Muney
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0204/07/2016-17

Date : 02/08/2016

AMBIENT AIR QUALITY MONITORING REPORT

Name of company : JINDAL SAW LIMITED
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 5182_2/6/10/23

Sr.No.	Particulars	Unit	AAQM - 1 (S)	AAQM - 2 (SSW)	AAQM - 3. (WSW)	AAQM - 4 (NW)
01.	Location of Ambient	---	Old Colony (Nr. Environment Laboratory)	Nr. Rain Water Harvesting Pond	LPG Yard (Nr. Water Reservoir)	Between Sinter - 2 & Spiral - 2
02.	Date of sampling	---	12/07/2016	12/07/2016	13/07/2016	13/07/2016
03.	Time of sampling	---	8.15	8.40	8.30	9.00
04.	Duration of Sampling	Min.	1440.00	1440.00	1440.00	1440.00
05.	Dominant Wind Direction (From)	---	WSW	WSW	W	W
06.	Average Wind Speed	Km/Hr.	11.8	19.2	11.3	11.3
07.	Average flow rate during sampling	m3/Hr.	1.0	1.0	1.0	1.0
08.	Average flow rate for Gas sampling	LPM	0.2	0.2	0.2	0.2
09.	Permissible limits for PM 10*	µg/m3	100	100	100	100
10.	Measured Concentration of PM 10	µg/m3	37	48	55	40
11.	Permissible limits for PM 2.5*	µg/m3	60	60	60	60
12.	Measured Concentration of PM 2.5	µg/m3	18	20	22	16
13.	Permissible limits for SO ₂ *	µg/m3	80	80	80	80
14.	Measured Concentration of SO ₂	µg/m3	1.4	2.7	4.2	3.9
15.	Permissible limits for NO ₂ *	µg/m3	80	80	80	80
16.	Measured Concentration of NO ₂	µg/m3	9.3	12.7	13.6	12.5
17.	Permissible limit for CO **	µg/m3	2000	2000	2000	2000
18.	Measured Concentration of CO	µg/m3	BDL	BDL	BDL	BDL

Instrument used : (1) Ecotech make 3 Nos. RDS (APM - 217 BL), (2) 3 Nos. Gaseous Sampling Kit (APM 109), & 3 Nos. PM 2.5 Sampler (AAS 127)

All Calibration due on : 15/05/2017

*Permissible Limits are as per NAAQ Standard 16th November 2009.

BDL= Below Detectable Limit

Royal Environment Auditing & Consultancy Service



Mumey
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 0205/07/2016-17

Date : 02/08/2016

AMBIENT AIR QUALITY MONITORING REPORT

Name of company : JINDAL SAW LIMITED
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 5182_2/6/10/23

Sr. No.	Particulars	Unit	AAQM - 5 (NE)	AAQM - 6 (SE)	AAQM - 7 (ESE)	AAQM - 8 (E)
01.	Location of Ambient	---	Vikashpuram Colony	Savitri Vihar Colony (Shopping Centre)	VIP Guest House	Main Gate
02.	Date of sampling	---	14/07/2016	14/07/2016	15/07/2016	15/07/2016
03.	Time of sampling	---	8.45	9.15	9.05	9.30
04.	Duration of Sampling	Min.	1440.00	1440.00	1440.00	1440.00
05.	Dominant Wind Direction (From)	---	WSW	WSW	W	W
06.	Average Wind Speed	Km/Hr.	8.2	8.2	1.6	1.6
07.	Average flow rate during sampling	m3/Hr.	1.0	1.0	1.0	1.0
08.	Average flow rate for Gas sampling	LPM	0.2	0.2	0.2	0.2
09.	Permissible limits for PM 10*	µg/m3	100	100	100	100
10.	Measured Concentration of PM 10	µg/m3	39	46	51	44
11.	Permissible limits for PM 2.5*	µg/m3	60	60	60	60
12.	Measured Concentration of PM 2.5	µg/m3	19	24	23	21
13.	Permissible limits for SO ₂ *	µg/m3	80	80	80	80
14.	Measured Concentration of SO ₂	µg/m3	5.1	5.9	4.1	6.2
15.	Permissible limits for NO ₂ *	µg/m3	80	80	80	80
16.	Measured Concentration of NO ₂	µg/m3	11.9	10.8	12.1	14.2
17.	Permissible limit for CO **	µg/m3	2000	2000	2000	2000
18.	Measured Concentration of CO	µg/m3	BDL	BDL	BDL	BDL

Instrument used : (1) Ecotech make 3 Nos. RDS (APM - 217 BL), (2) 3 Nos. Gaseous Sampling Kit (APM 109), & 3 Nos. PM 2.5 Sampler (AAS 127)

All Calibration due on : 15/05/2017

BDL= Below Detectable Limit

*Permissible Limits are as per NAAQ Standard 16th November 2009.

Royal Environment Auditing & Consultancy Service



Muney
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. :0206/07/2016-17

Date : 02/08/2016

FUGITIVE EMISSION MONITORING REPORT

Name of company : JINDAL SAW LIMITED

Village: Samaghogha,

Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 5182_Part - 2/6/10/23/22

Sr. No.	Particulars	Unit	A - 1	A - 2	A - 3
01.	Location of Ambient	---	RMH Junction House	RMH Stock House	Sinter RMH Yard
02.	Date of sampling	---	19/07/2016	19/07/2016	20/07/2016
03.	Time of sampling	---	8.00	8.30	8.15
04.	Duration of Sampling	Hr.	8.00	8.00	8.00
05.	Dominant Wind Direction (From)	---	WSW	WSW	WSW
06.	Average Wind Speed	Km/Hr.	7.0	7.0	8.5
07.	Average flow rate during sampling	m3/Hr.	1.0	1.0	1.0
08.	Average flow rate for Gas sampling	LPM	0.2	0.2	0.2
09.	Permissible limits for PM 10*	µg/m3	3000	3000	3000
10.	Measured Concentration of PM 10	µg/m3	1953	1818	1733
11.	Permissible limits for SO2*	µg/m3	150	150	150
12.	Measured Concentration of SO2	µg/m3	18.6	17.5	19.4
13.	Permissible limits for NO2*	µg/m3	120	120	120
14.	Measured Concentration of NO2	µg/m3	25.1	26.3	24.5
15.	Permissible limit for CO **	µg/m3	2000	2000	2000
16.	Measured Concentration of CO	µg/m3	BDL	BDL	BDL
17.	Permissible limit for Pb*	µg/m3	2	2	2
18.	Measured Concentration of Pb	µg/m3	ND	ND	ND

Instrument used : (1) 3 Nos. RDS (APM - 217 BL), (2) 3 Nos. Gaseous Sampler (APM 109)

All Calibration due on : 15/05/2017

BDL= Below Detectable Limit

ND= Not Detectable

Royal Environment Auditing & Consultancy Service



Munej
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. :0207/07/2016-17

Date : 02/08/2016

FUGITIVE EMISSION MONITORING REPORT

Name of company : JINDAL SAW LIMITED
Village: Samaghogha,
Tal. : Mundra, Dist. Kutch

Test Method : As per IS Standards - 5182_Part - 2/6/10/23/22

Sr. No.	Particulars	Unit	A - 4	A - 5	A - 6
01.	Location of Ambient	---	Sinter 2 Ground Hopper	DISP "CCM" Area	BF CAST HOUSE
02.	Date of sampling	---	20/07/2016	21/07/2016	21/07/2016
03.	Time of sampling	---	8.35	8.10	8.25
04.	Duration of Sampling	Hr.	8.00	8.00	8.00
05.	Dominant Wind Direction (From)	---	WSW	W	W
06.	Average Wind Speed	Km/Hr.	8.5	12.0	12.0
07.	Average flow rate during sampling	m3/Hr.	1.0	1.0	1.0
08.	Average flow rate for Gas sampling	LPM	0.2	0.2	0.2
09.	Permissible limits for PM 10*	µg/m3	3000	3000	3000
10.	Measured Concentration of PM 10	µg/m3	1146	513	1857
11.	Permissible limits for SO2*	µg/m3	150	150	150
12.	Measured Concentration of SO2	µg/m3	14.6	20.5	17.1
13.	Permissible limits for NO2*	µg/m3	120	120	120
14.	Measured Concentration of NO2	µg/m3	21.3	27.2	25.2
15.	Permissible limit for CO **	µg/m3	2000	2000	2000
16.	Measured Concentration of CO	µg/m3	BDL	BDL	BDL
17.	Permissible limit for Pb*	µg/m3	2	2	2
18.	Measured Concentration of Pb	µg/m3	ND	ND	ND

Instrument used : (1) 3 Nos. RDS (APM - 217 BL), (2) 3 Nos. Gaseous Sampler (APM 109)
All Calibration due on : 15/05/2017

BDL= Below Detectable Limit
ND= Not Detectable

Royal Environment Auditing & Consultancy Service



Mehraj
Analyst